

U. S. Coast Guard Inspections

MST1 Nathan Frerichs

Applicability

- Each facility that is capable of transferring oil or hazardous materials, in bulk, to or from a vessel, where the vessel has a total capacity of 250 barrels (10,500 gallons) or more

What do you need?

- Letter of Intent
 - 33CFR154.110
- Operations Manual
 - 33CFR154.300
- Response Plan
 - 33CFR154.1010

What is regulated by C.G.

- Only oil or hazmat delivered from the vessel is a regulated transfer.
- If fuel is delivered by truck plane or rail it is not a C.G. regulated transfer.

Lessons Learned

- Multiple Facilities with one tank farm
- Pipeline Pressure test
 - 33CFR156.170
- Facilities do not have designated Person in charge
- Containment around tank farms
 - 40CFR112.7

Questions?

U.S. Coast Guard Sector Anchorage

Facilities Inspections

P.O. Box 5800

JBER AK 99505-0800

(907) 428-4200